

520 South Main Street
Suite 2531
Akron, OH 44311
PH 330.572.2100
FX 330.572.2102

The Akron Architectural Group

Braun & Steidl Architects ▪ GPD Group ▪ Hasenstab Architects, Inc. ▪ Moody Nolan, Inc. ▪ TC Architects, Incorporated ▪ URS

AKRON PUBLIC SCHOOLS

Schematic Design Community Planning Team Meeting #3
Voris Community Learning Center
Wednesday July 21 @ 6:00 p.m.

In Attendance

K. Waller	AAG
J. Novak.....	AAG
F. Herr.....	Akron Public Schools
R. Mikula.....	Akron Public Schools
G. Wolfe.....	School Staff
J. Bucy.....	School Staff
W. Miller.....	CPT
S. Taylor	YMCA

Distribution

AAG Project Managers

M. Salopek.....	AAG
D. Mitchell.....	AAG
D. James.....	Akron Public Schools
J. Beal.....	Akron Public Schools
K. Ingram.....	Akron Public Schools
L. Duncan	City of Akron
T. Long.....	City of Akron
M. Williamson	City of Akron
D. Krutz.....	RKPS
L. Jennings	Burges and Burges

The following is a review of items discussed at the meeting:

1. F. Herr and CPT agreed that the Special Education Workroom would be better served if it were accessed directly from the corridor as opposed to through the Special Education Resource Room. This would prevent activity in the Resource Room from being disrupted when accessing the work room.
2. OSFC now accepts rubberized sports surfaces for gymnasium floors and stated that would be a preference for the CLC over VCT.

3. Because the Kindergarten classrooms exceed 1,000 sf, 2 exits would be required by code. The APS will determine if the additional door would be located along the corridor wall or the exterior wall of the classroom.
4. A desire was expressed to see the canopy on the east side of the building extended farther so that it terminated in a way similar to the canopy over the main entrance. Could this be a part of the base bid? K. Waller said he did not have the precise cost implication but that it could be included as a part of the base bid.
5. The group discussed adjustments that could be made to the design so that the building forms related more closely to the plan design of the building. One point was to eliminate the higher canopy as it is redundant as a shelter from precipitation and does not connect meaningfully with what is going on inside of the building. Another point was to raise the roof of the Media Center and cap it with a flat roof instead of the pitched from currently shown in elevation.
6. F. Herr suggested the elimination the punched window openings on the west end of the classroom wing citing the quality of views from windows in the stair and the differential of window-to-wall space between classrooms.
7. K. Waller will present a final elevation proposal at the following meeting. Some of the images may have color to more meaningfully illustrate the appearance of the building.
8. The next and final CPT meeting during the SD Phase will take place on August 18, at 6:00

The preceding is AAG's interpretation of the meeting. Any changes, additions, or clarifications should be forwarded to our office as soon as possible. Unless these changes are furnished within ten (10) working days, it will be understood that all parties are in agreement with the preceding statements.